

**BOROUGH OF COLLINGSWOOD
HISTORIC PRESERVATION COMMISSION
CERTIFICATION OF APPROPRIATENESS**

Property Address: 19 Gorman Ave. **Name:** Marlene Hummel

Tax Block # 110

Lot # 11

On 4/12/07 the Commission _____ approved, X approved with conditions, _____ denied, _____ tabled, or _____ deemed incomplete the application as presented by the applicant.


Chairperson Signature

Date: April 12, 2007

FINDINGS

To approve the application for the replacement of the railing with the following conditions:

If approved with conditions, the conditions were the following:

- That the railing is constructed in accordance to N.J. Sub code for height.
- That the railing matches the existing wooden railing and/or at a minimum of 30 inches in height.
- That if the applicant wishes to replace the porch flooring it would be approved but only if the flooring is replaced with tongue -and- groove.
- That the railing and flooring be painted.

That the application must comply with the Chapter 141 Borough of Collingswood Development Regulations & New Jersey Uniform Construction Code.

Further Conditions: Y/N

Field Committee Report: Y/N

The above application, decision, and any attached materials shall be presented to the Construction Code Office within 10 days of the Commission's decision for its referral to other boards or agencies.